FORMAT FOR UPLOADING THE CETP MONITORING DATA ON SPCBS WEBSITE

S. No.	Name and Address the CETP	Capacity (MLD)	Design inlet quality	Final effluent quality standard or ZLD condition	Date of Monitoring	Waste water treated in CETP (MLD)	Waste water by passed untreated in the area. If any (MLD)	Observed Inlet Quality	Observed Final effluent quality	Status of online CEQMS	Status of hazardous storage/ Disposal
1	2	3	4	5	6	7	8	9	10	11	12
1.	Govindpura Audhyogic Kshetra Pradushan Niwaran Kendra, Plot no. 28, Sector-H, Industrial Area Govindpura, Bhopal- 462023	0.600	BOD 1820 mg/l	pH- 6.5-9.0	09.10.2018	0.201 ML Day in October 2018	Nil	pH- 6.79	pH- 7.27	Installed	N.A.
			COD 3200 mg/l	BOD – 30 mg/l				BOD - 466.6 mg/l	BOD – 20 mg/l		
			CN- 0.20 mg/l	TSS – 100 mg/l				TSS – 422 mg/l	TSS – 84 mg/l		
				COD – 250 mg/l				COD – 2100 mg/l	COD – 100 mg/l		
				TDS – 2100 mg/l				TDS – 1994 mg/l	TDS – 1400 mg/l		

R.S. BHARTI
Junior Scientist
Regional Office, MPPCB, Bhopal